



PESHAWAR ELECTRIC SUPPLY COMPANY

OFFICE OF THE CHIEF EXECUTIVE OFFICER PESCO

225,227-WAPDA HOUSE PESHAWAR.

Ph: No..9212011, 091-9214147

FAX NO./CE (O&M) Distrib:DCM&O/23/26/1739-48

Dated 10/10/2017

The S.E (GSO) Circle PESCO,
Peshawar.

Subject: SHUT DOWNS

Reference: Your letter No.3436 06/10/2017.


Approval is hereby conveyed for the following shut downs. Date, time & purpose is mentioned against it. Please direct the work-executing agency to complete the entire work within time allowed otherwise they will be responsible for the consequences. Also, submit progress of the shut down may be intimated to this office for the information of high-ups as desired.

Name of Transmission line /Grid Station.	Date & Time.	Area Affected.	PURPOSE
Shut down on 66 kv Breaker BKI-82 controlling 10/13MVA 66/11 KV Power Transformer T-2 at 66kv GSS Bandkurai.	From 0800 hrs dated 11.10.2017 to 1600 hrs dated 14/10/2017 (Duration 80 hrs)	<u>11kv Paharur, Panyala, Yarik, Awan, Abdul Khel, Al Moiz Sugar Mill feeder,</u> <u>However with the co-operation of Operation Staff supply to the affected feeders will be arranged from the adjacent feeders alternately with partial load shedding</u>	For dehydration of transformer Oil of 10/13MVA ,66/11kv Power Transformer T-2 due to weak insulation Resistance.

This is issued with the approval of Competent Authority.

CC:

- 1 Commissioner DIKhan Division for information please.
- 2 C.E (O&M) Dist: PESCO HQ Peshawar for information please.
- 3 C.E (O&M) (T&G) PESCO HQ Peshawar for information please.
- 4 Chief Operation Officer PESCO HQ Peshawar for information please.
- 5 S.O (Tech) to CEO PESCO HQ Peshawar for information please.
- 6 SE (Operation) PESCO Bannu Circle. SE Bannu Circle w/r to his NOC to SE GSO Circle PESCO Peshawar. He is requested inform all the important consumers/ Industrial consumers including DCO, Nazims, Naib Nazims, Councilors and others Public representatives FM Radio and announcement in the area Masajid accordingly. Also inform the field formation to carryout proper maint: of 11kv line during this shut down so as to minimize the faults
- 7 Director RCC / NPCC Islamabad for information & further n. action pl.
- 8 SO (PCMC) Home Deptt: Peshawar for information and n.action please.
- 9 Incharge Central Complaint Cell PESCO H/Q, Peshawar.
- 10 Dy: Director PDC PESCO HQ for information and necessary action please.


DY: DIRECTOR (OPR) CM&O
PESCO HQ, PESHAWAR