



PESHAWAR ELECTRIC SUPPLY COMPANY

OFFICE OF THE CHIEF EXECUTIVE OFFICER PESCO

225,227-WAPDA HOUSE PESHAWAR.

Ph: No.091-9212011 Fax 091- 9214147

FAX NO. /C.E (O&M) Distrib: /M&O/26/36/ 3045-53

Dated 10/07/2018

The SE GSO Circle,
Peshawar

Subject: **SHUT DOWNS.**

Reference: Your letter Fax No 2217 dated 03/07/2018

Approval is hereby conveyed for the following shutdowns. Date, time & purpose is mentioned against it. Please direct the work-executing agency to complete the entire work within time allowed otherwise they will be responsible for the consequences. Also, progress of the shut down may be intimated to this office for the information of high-ups as desired.

NAME OF GSS/ EQUIPMENT	DATE & TIME	AREA EFFECTED.	PURPOSE
Shut down on 7.5MVA, 66/11kv Power Transformer T-1 at 66kv GSS Band Kurai.	14/07/2018 0800-1200 hrs (04 Hours Duration)	11kv Dhakki, Scarp-1 & 2,	For General maintenance and protection testing of Power T/F a/w 11kv in- coming and out going breakers.
Shut down on 10/13MVA,66kv Power T/f T-2 (controlling 66kv Breaker BKI-82) at 66kv GSS Bandkurai.	14/07/2018 1200-1700 hrs (05 Hours Duration)	11kv Paharpur, Panyala, Yarik, Awan, Abdul Kihel, A-Moiz Sugar Mill.	

This issued with the approval of Chief Executive Officer PESCO.

CC:

1. Commissioner DIKHAN Division for information please.
2. C.E (O&M) (T&G) PESCO HQ Peshawar for information please.
3. **S.E (Operation) PESCO Bannu Circle Bannu w/r to his NOC directly conveyed to GSO Circle Peshawar.. He is requested to inform all the important consumers/ Industrial consumers including DCO, Nazims, Naib Nazims, Councilors and others Public representatives FM Radio and announcement in the area Masajid accordingly. Also inform the field formation to carryout proper maint: of 11kv line during this shut down so as to minimize the faults.**
4. Director RCC / NPCC Islamabad or information & further necessary action please.
5. DG (Public Relation) PESCO HQ Peshawar to publish the above shut down widely through Print / Electronic Media for the information of General Public please.
6. Addl: DG (MIS) PESCO with the request **to upload the shut downs on PESCO Website for the information of General Public** under the direction of Ministry of Energy (Power) Division Islamabad
7. Dy: Director PDC PESCO HQ Peshawar with the request to give relief in scheduled load Shedding to the above feeders after the shut down as desired by C.E.O PESCO.
8. XEN (SS&TL) (E) Division PESCO Bannu w/r to above for inf: and n. action.
9. SO (PCMC) Home Deptt:Peshawar for information and n.action please. (Fax 9210201)
10. Incharge PCCC PESCO H/Q Peshawar for information. He is advised to keep Strict watch over the timings of the shut down / PTW.

DY:DIRECTOR (OPT) CM&O
PESCO HQ PESHAWAR



PESHAWAR ELECTRIC SUPPLY COMPANY

OFFICE OF THE CHIEF EXECUTIVE OFFICER PESCO
225,227-WAPDA HOUSE PESHAWAR.
Ph: No.9212011 Fax No.921240

FAX NO. /CE(O&M)DISTRIB/DCM&O/M&O/ 3032-41

Dated: 09/07/2018

The SE GSO Circle FESCO,
Peshawar.

Subject: **SHUT DOWNS**

Reference: Your letter No.2231,2230, 2227, 2225,2238, 2226, 2237 dated 06/07/2018
Approval is hereby conveyed for the following shut downs. Date, time & purpose is mentioned against it. Please direct the work-executing agency to complete the entire work within time allowed otherwise they will be responsible for the consequences. Also, submit progress of the shut down may be intimated to this office for the information of high-ups as desired.

NAME OF GSS/ EQUIPMENT	DATE & TIME	AREA EFFECTED.	PURPOSE
Shut down on 132kV Transmission Line AMC-Mansehra Section, Controlling 132kV Breaker AMC-2, At 132kV GSS AMC Abbott Abad.	10.07.2018 0900-1600 hrs Duration 07 hrs	No area will be affected if power supply restored from 132kV GSS Abbott Abad to 132kV GSS AMC.	For Routine / Preventive Maintenance work.
Shut down on 132kV Transmission Line Haripur-Abbott Abad Section, Controlling 132kV Breaker HRP-8, At 132kV GSS Haripur.	10.07.2018 0900-1600 hrs Duration 07 hrs	1-132 KV GSS A/Abad (11 KV O/G Link Road, Bagnoter, Cantt, Dhamtor, Thandayani, Sherwan, Town, Kehal, Nawasher). 2-132 KV GSS AMC (11 KV O/G Jhangi, APS, Mandian, Tanawal, BPK.). 3-132 KV GSS Balakot (11KV Bala Kot, Garhi Habib Ullah & Bohi. 4-132 KV GSS Oghi (11 KV O/G Darband, Sussal Gali, Oghi). 5-132 KV GSS N/Gali (11 KV O/G Ayubia, N/Gali, Makkol, POF). 6-132KV GSS Mansehra:- (11KV O/G Attar Shesha, City-2 & 3, Perhana, Baffa, Dadar, Khaki, Qalanderabad, Ghazikot, Muradpur, Mangloor, Shinkiyari, Lassan Nawab & Pakhal.	For Routine / Preventive Maintenance work.
Shut down on 40MVA, 132/11kV Power T-3, At 132kV GSS Daggar.	11.07.2018 1000-1300 hrs Duration 03 hrs	11k V O/G Soni Gram, Dewana Baba, Ambela & Achini.	For Preventive / Protection Testig.
Shutdown on 132KV Single Circuit T/Line Mardan-Jehangira Section, Controlling Breaker E7Q1, At 220kVGSS Mardan.	11.07.2018 0900-1600 hrs Duration 07 hrs	No area will be affected as other source is available.	For Preventive Maintenance of Transmission Line.
Shutdown on 132kV Breaker TNK-84, Controlling, 20/26MVA, 132/11kV Power Transformer T-4, At 132kV GSS Tank.	11.07.2018 0900-1300 hrs Duration 04 hrs	11kV O/G Dabara, Ranwal & Kot Azam-2.	For General Maintenance & Protection Testing of Power Transformer T-4 alongwith 132kV Breaker TNK-84 & all 11kV Breakers.

Shutdown on 132kV Breaker TNK-86, Controlling, 20/26MVA, 132/11kV Power Transformer T-6, At 132kV GSS Tank.	11.07.2018 1300-1700 hrs Duration 04 hrs	11kV O/G Sabir Baba, Gul Imam, Mulzai-1 & Tank City-1	For General Maintenance & Protection Testing of Power Transformer T-6 alongwith 132kV Breaker TNK-86 & all 11kV Breakers.
Shutdown on 132kV Single Circuit T/line Jehangira-Gondal Section, Controlling 132kV Breaker JNG-1, At 132kV GSS Jehangira.	12.07.2018 0900-1600 hrs Duration 07 hrs	No area will be affected as other source is available.	For Preventive Maintenance of Transmission Line.
Shutdown on 132kV T/line Dalazak-Peshawar City-New Shahi Bagh Section, Controlling Breaker DLK-1, At 132kV GSS Dalazak.	12.07.2018 0800-1300 hrs Duration 05 hrs	No area will be affected.	For replacement of defective SF-6 Pressure gauge of 132kV Breaker DLK-1.

This is issued with the approval of competent authority.

CC:

- 1- **Commissioner Hazara/ Malakand, Kohat, Bannu for Information please.**
- 2- C.E (O&M) Dist: PESCO HQ Peshawar for information please.
- 3- C.E (O&M) (T&G) PESCO HQ Peshawar for information please
- 4- Chief Operation Officer PESCO HQ Peshawar for information please.
- 5- S.O (Tech) to CEO PESCO HQ Peshawar for information please.
- 6 **SE (Operation) PESCO Hazara Circle Abbottabad & SE Bannu Circle, Swat circle w/r to their NOC conveyed to SE GSO Circle Peshawar. They are requested to inform all the important consumers/ Industrial consumers including DCO, Nazims, Naib Nazims, Councilors and other Public representatives FM Radio and announcement in the area Masajid accordingly. Also inform the field formation to carryout proper maint: of 11kv line during this shut down so as to minimize the fault.**
7. **Director RCC / NPCC Islamabad or Information & further necessary action please.**
8. **I/Charge Crises Management Cell NWFP Peshawar for Inf. please.**
9. **I/Charge Crises Management Cell PESCO HQ for Information.**
- 10 **DG (Public Relation) PESCO HQ Peshawar to publish the above shut down widely through Print / Electronic Media for the Inf of General Public please.**
11. **Addl Director PDC PESCO HQ for Inf: and relief in scheduled load shedding after the shut down please.**

DY: DIRECTOR (OP) CM&O
PESCO HQ Peshawar